



818 S. FLORES ST. SAN ANTONIO, TEXAS 78204 www.saha.org

Procurement Department

ADDENDUM # 2

To: 0912-658-80-3102

RFP for: Clothes Line Poles @ Wheatley

Please note the response to the following question asked at the pre-submittal conference:

Question 1: What is the contractor supposed to do with the spoilage from the holes drilled to set the poles?

Answer 1: The dirt removed shall be spread evenly around the area. Do not leave mounds of dirt. All concrete and other nonorganic materials must be disposed of off site.

By: Charles R Bode
Charles Bode, Asst. Director of Procurement

Date: February 5, 2010