



818 S. FLORES ST.    SAN ANTONIO, TEXAS 78204    www.saha.org

Procurement Department

## ADDENDUM #1

**To: 0912-988-15-3105**  
**RFQ for Fence at Springview**  
**Date: January 12, 2010**

---

**A) Question 1: What are the panels made of?**

**Answer 1: Steel**

**B) Question 2: Are the panels used?**

**Answer 2: Yes**

**C) Additional Specifications:**

1. There are two sections that measure a total of 173 ft. and will be at the Southside of The Convent Bldg. A gate will be located where the #2 is placed on the map.

2. The section that measures 140' ft. will be facing the Westside area of Bldg. B. Installation to began at the entry wall (By Entry Doors to Bldg. B) and connect to an existing iron fence at the end of bldg. by marker #3

Marker #3 is an existing fence, and the new fabricated fence panel will connect to it. There is a 6' foot iron fence panel at, Marker #4. Hinges will need to be welded on this panel so that it can be opened for access to the closed area. Area at Marker #1 will have a gate.

Vendor will supply 3" square tubing (post) where iron panels will be welded. All Iron post will be placed in concrete; with a 24" inch post depth

Note: Fabricated Iron Fence Panels that Springview is supplying:

1" Square Tubing 68" long (vertical) and welded on 2" Angle Iron, 8' ft. wide.

Contact: Ignacio Valles

Cell # 559-2263

By: Charles R. Bode

Charles Bode, Asst. Director of Procurement

Date: January 13, 2010



818 S. FLORES ST. ① SAN ANTONIO, TEXAS 78204 ①

[www.saha.org](http://www.saha.org)

**Attached:  
Photos of Panels  
Map with Fence and Gate Locations**



**Panels**



**Panels**



818 S. FLORES ST.

SAN ANTONIO, TEXAS 78204

[www.saha.org](http://www.saha.org)



**Panels**



Fence to go along sidewalk



818 S. FLORES ST.



SAN ANTONIO, TEXAS 78204



[www.saha.org](http://www.saha.org)



Fence to go in front of the trees; the length of the B



Attach new fencing to existing fence (no gaps)





818 S. FLORES ST.

SAN ANTONIO, TEXAS 78204

[www.saha.org](http://www.saha.org)



Fence to go behind the hedges (lengthwise)



Fence to go length of the hedges in front of The Convent



818 S. FLORES ST.

SAN ANTONIO, TEXAS 78204

[www.saha.org](http://www.saha.org)



Gate install here by The Convent; second gate at sidewalk between the hedges and B Building.



example of panels that we have (materials).

C-RTMFC ←

EMER  
NOOD  
1000

NOTE  
#1 5' OPENING  
IRON GATE  
#2 5' FT OPENING  
IRON GATE

North  
↑

TOTAL END 173' TO END  
Ft.

ATTN: CARLTON  
BOTTOMS

140' Ft.

Bldg. B

BUS B  
FIRE PASS

EXISTING  
#3 FENCE

P-44  
E 2001  
AD  
TR 20  
NW  
TR 40

AD  
NW  
TR 20  
E 2001  
NW  
TR 40

