



818 S. FLORES ST. ① SAN ANTONIO, TEXAS 78204 ① www.saha.org

Procurement Department

ADDENDUM #3

To: 1001-936-37-3123

RFP for Installation of Gate Operator at Villa Tranchese

Date: March 18, 2010

Question 1: Is there an existing system to open the gate or pedestrian gates?

Answer 1: No, this is a new system installation. Power will be supplied at or near the gates.

Question 2: Do we need to match existing cards?

Answer 2: Yes, the cards for the pedestrian gates must match the current cards that are used for the front entrance to the building.

Question 3: Do we need to match existing front entrance to the building cards for the vehicular gates?

Answer 3: No, the vehicular gates will use RF Technology. The Contractor shall supply forty (40) RF controllers with the system.

By: Charles R Bode
Charles Bode, Asst. Director of Procurement

Date: March 18, 2010