



818 S. FLORES ST. SAN ANTONIO, TEXAS 78204 www.saha.org

Procurement Department

ADDENDUM #1

To: 1003-650-38-3155

RFQ for Supply and Install Playground Equipment at Alazan, Cheryl West, TL Shaley, and Westway

Date: April 8, 2010

Question 1: At Westway Apartments Playground 1 – in the Prep section it states “Prep playground area, dimensions: approximately 3,451 square feet to 2% positive drainage”..., but in the Equipment to be installed section it states “Poured in place safety surfacing system (softfall), approximately 151’ circumference... How large a softfall area will Playground 1 require?

Answer 1: Playground 1 will require three separate areas located around the existing equipment, the dimensions for the areas are approximately 23’x51’, 27’x34’ and 34’x40’. Approximately 3,451 square feet.

Clarification: The 4” aggregate base referenced in the Prep sections of the specifications shall be a ¾” aggregate base. The base shall be Road Grade Class II or ABC aggregate mixture containing ¾” rock, dirt and sometimes small amounts of sand. Clean stones or larger stones are not acceptable.

By: Charles R Bode
Charles Bode, Asst. Director of Procurement

Date: April 9, 2010