



818 S. FLORES ST. ① SAN ANTONIO, TEXAS 78204 ① www.saha.org

Procurement Department

ADDENDUM #4

To: 1009-909-77-3331
RFQ for Boarding Up Vacant Houses
Date: October 19, 2010

Question 1: SAHA is requesting some bolts to be used in this project but does not specify what diameter is required.

Answer 1: The bolts shall be 3/8" X 10".

Question 2: Does the plywood need to be painted on both sides?

Answer 2: Yes, the plywood must be painted on both sides.

By: Carl Bottoms
Procurement Supervisor

Date: October 19, 2010