



818 S. FLORES ST. ① SAN ANTONIO, TEXAS 78204 ① www.saha.org

Procurement Department

## **ADDENDUM #1**

**To: RFQ# 1105-910-54-3528  
Paint Buildings at Cisneros**  
**Date: May 31, 2011**  
**From: Carl Bottoms**

---

**Question 1: Does the handrail paint?**  
**Answer 1: Yes**

**Question 2: Do the metal columns associated with the walkway canopy paint?**  
**Answer 2: Yes**

**Question 3: Does the privacy fences attached to the buildings paint/stain?**  
**Answer 3: Yes, stain**

**Question 4: Does the brick of the buildings get cleaned with the water blast?**  
**Answer 4: Yes**

**Question 5: The scope of work states that all exterior of the community building gets power washed. Does this include the brick**  
**Answer 5: Yes**

**Question 6: Is this expected to be a one or two coat paint job?**  
**Answer 6: Two coats using acrylic latex**

**By: Carl Bottoms**  
**Procurement Supervisor**

**Date: May 31, 2011**