



818 S. FLORES ST.

SAN ANTONIO, TEXAS 78204

www.saha.org

Procurement Department

## **ADDENDUM # 5**

**To: 1106-910-38-3551**

**IFB for: Asbestos Abatement of the Marie McGuire Apartments**

---

**The closing date and time is extended to July 20, 2011 at 11:00 a.m.**

Please note the following clarifications from previous addenda:

**Clarification 1:** Regarding Addendum #2, fourth question; The San Antonio Housing Authority has retained Professional Service Industries, Inc. (PSI) to provide the environmental ambient air monitoring and air clearance testing for this project. The Abatement Contractor shall be responsible for conducting Occupational Safety & Health Administration (OSHA) personal monitoring of their workers.

**Clarification 2:** Regarding Addendum #4, additional information; The issue of how to manage the potentially asbestos-contaminated floor float: The Contractor shall provide allowance in their bid to account for 25% of the entire flooring abatement work area to have asbestos-contaminated float material to be removed and handled as an ACM. Asbestos mastic is suspected to lie underneath some of the existing float material. The actual quantity of this asbestos-contaminated float material will be monitored by the Owner's Representative during removal, for the purpose of post-abatement accounting of the final material quantity related to the project costs.

By: *Charles R Bode*  
Charles Bode Asst. Director of Procurement

Date: July 12, 2011