



ADDENDUM #1

To: RFQ # 1108-031-05-3584

For: Install drain lines at Sun Park

Date: October 28, 2011

The deadline to submit quotes for RFQ # 1108-031-05-3584 Install drain lines at Sun Park has been extended to November 4, 2011 at 11:00am.

Question 1: Can you tell me if we are installing a drip pan for each a/c unit or one large drip pan to cover two a/c units?

Answer 1: One large drip pan to cover two a/c units.

By: *Carl Bottoms*

Carl Bottoms, Procurement Supervisor

Date: October 28, 2011