



818 S. FLORES ST. ① SAN ANTONIO, TEXAS 78204 ① www.saha.org

Procurement Department

ADDENDUM #1

To: 1111-910-51-3660
RFQ for Sidewalk-Driveway Replacement at 14054 Greenjay
Date: December 19, 2011

Question 1: Do you want the sidewalk at Greenjay to be sloped to meet the neighbor's sidewalk? That way it will be ADA compliant.

Answer 1: Yes, the new and existing sidewalk must finish at the same height.

By: Carl Bottoms
Procurement Supervisor

Date: December 19, 2011