

PROPERTY INSPECTION REPORT

Prepared For: SAHA (Name of Client)
San Antonio, TX 78237

Concerning: 4022 El Paso (Address or Other Identification of Inspected Property)

by: Jon Krauss 4255 02/21/08 (Date)
(Name and License Number of Inspector)

(Name, License Number and Signature of Sponsoring Inspector, if required)

The inspection of the property listed above must be performed in compliance with the rules of the Texas Real Estate Commission (TREC).

The inspection is of conditions which are present and visible at the time of the inspection, and all of the equipment is operated in normal modes. The inspector must indicate which items are in need of repair or are not functioning and will report on all applicable items required by TREC rules.

This report is intended to provide you with information concerning the condition of the property at the time of inspection. Please read the report carefully. If any item is unclear, you should request the inspector to provide clarification.

It is recommended that you obtain as much history as is available concerning this property. This historical information may include copies of any seller's disclosures, previous inspection or engineering reports, reports performed for or by relocation companies, municipal inspection departments, lenders, insurers, and appraisers. You should attempt to determine whether repairs, renovation, remodeling, additions or other such activities have taken place at this property.

Property conditions change with time and use. Since this report is provided for the specific benefit of the client(s), secondary readers of this information should hire a licensed inspector to perform an inspection to meet their specific needs and to obtain current information concerning this property.

ADDITIONAL INFORMATION PROVIDED BY INSPECTOR

Report Number: 20080241931 Phone Number: _____
Date of Inspection: 02/21/08 Fax Number: _____
Time of Inspection: _____
Client Mailing Address: _____
City/State/Zip: _____

SPECIAL NOTES:

Additional pages may be attached to this report. Read them very carefully. This report may not be complete without the attachments. If an item is present in the property but is not inspected, the "NI" column will be checked and an explanation is necessary. Comments may be provided by the inspector whether or not an item is deemed in need of repair.

I=Inspected		NI=Not Inspected		NP=Not Present		R=Not Functioning or in Need of Repair		Inspection Item
I	NI	NP	R					

I. STRUCTURAL SYSTEMS

A. Foundations (If all crawl space areas are not inspected, provide an explanation.)
Comments (An opinion on performance is mandatory.):
 FOUNDATION TYPE- Concrete slab on grade.
 CONCRETE FOUNDATION OBSERVATIONS- Foundation appears to be functioning normally at time of inspection.
 Minor signs of past settlement observed in the form of hair line type cracking to finished surfaces.

B. Grading and Drainage
Comments
 Structure is on a slightly sloped lot. Grade at foundation appears adequate at time of inspection
 Note: dry soil conditions at rear, at rear left. Regular watering should be done.

C. Roof Covering (If the roof is inaccessible, report the method used to inspect.)
Comments
 METHOD USED TO INSPECT ROOF- The following was observed upon walking on the roof.
 DESCRIPTION OF MATERIALS- Composition and/or fiberglass shingles. Note: Average life expectancy under normal installation/conditions is between 10 -14 years.
 ROOF COVERING OBSERVATIONS-Several nails on each roof slope backing out of shingles, in need of repairs
 Starter strip around perimeter edge of roof improperly installed, not sealed down.
 Exposed edge of roof decking at right base of valley areas, at rear left several areas, at right center on edge of roof in need of repair
 GUTTERING OBSERVATIONS- DAMAGE/DEFECTS NOTED- Gutter is sloped improperly and holding water at front of roof.

D. Roof Structure and Attic (If the attic is inaccessible, report the method used to inspect.)
Comments
 ACCESS METHOD/LIMITATIONS- Full access
 ATTIC OBSERVATIONS- Truss framing
 Upper vents not fully cut out in attic. Trim for full air flow.
 ROOF STRUCTURE OBSERVATIONS- Front porch truss top web member not making contact with hip truss. Add proper blocking
 INSULATION OBSERVATIONS- Blown type insulation (either fiberglass or rock wool) present. The insulation layer is approximately, 8 - 9 inches thick.

E. Walls (Interior and Exterior)
Comments

I=Inspected		NI=Not Inspected		NP=Not Present	R=Not Functioning or in Need of Repair	Inspection Item
I	NI	NP	R			

INTERIOR WALL OBSERVATIONS- INTERIOR WALLS ARE COVERED WITH THE FOLLOWING MATERIAL(S)- Drywall.
OBSERVATIONS- No problems observed during this inspection period.

EXTERIOR WALL OBSERVATIONS- EXTERIOR WALLS ARE CONSTRUCTED OF THE FOLLOWING MATERIALS-
Cement Fiber type siding. Soffit(s), eave(s), and/or trim are painted wood. Aluminum/ vinyl siding.
OBSERVATIONS-paint, seal base of wood trim at corners, around house.
deteriorated wood at fascia trim rear at diverter flashing over a/c unit, in need of repairs.

F. Ceilings and Floors
Comments

CEILING COVERING(S)- CEILING OBSERVATIONS- No problems observed during this inspection period.

G. Doors (Interior and Exterior)
Comments

INTERIOR DOOR OBSERVATIONS- No problems observed during this inspection period.

EXTERIOR DOOR OBSERVATIONS- No problems observed at this time.

H. Windows
Comments

OBSERVATIONS-swelling, water damaged window openings from leakage at master , at right side windows.
Missing screen at front bedroom window

I. Fireplace/Chimney
Comments

Not Present

J. Porches, Decks and Carports (Attached)
Comments

PORCH OBSERVATIONS- No problems observed during inspection period.

K. Other
Comments

Not Present

II. ELECTRICAL SYSTEMS

A. Service Entrance and Panels
Comments:

I=Inspected		NI=Not Inspected		NP=Not Present		R=Not Functioning or in Need of Repair		Inspection Item
I	NI	NP	R					

SERVICE COMMENTS: Under Ground
 MAIN PANEL COMMENTS: LOCATION- Exterior of house
 PREDOMINANT OVERLOAD PROTECTION DEVICES- Circuit breakers are provided.
MAIN ELECTRICAL PANEL OBSERVATIONS-white wires used as hot legs on circuits but not properly marked as hot legs.

SUB-PANEL COMMENTS: LOCATION- Garage
 SUB-ELECTRICAL PANEL OBSERVATIONS- No problem(s) noted at the time of inspection.

- B. Branch Circuits - Connected Devices and Fixtures** (Report as in need of repair the lack of ground fault circuit protection where required.):
Comments:

FEEDERS- Copper, Aluminum (220 volt OK)
 VISIBLE BRANCH WIRING TYPE- Grounded type branch wiring present. Copper
 BRANCH WIRING OBSERVATIONS- No problems observed during this inspection period.

III. HEATING, VENTILATION AND AIR CONDITIONING SYSTEMS

- A. Heating Equipment #1:**
Type/Energy Source: System Type- Electric Forced Air Heat Pump.
Comments:
 Unit is located in, closet
 Heating System- The heating system operated correctly at the time of the inspection.

- B. Cooling Equipment #1:**
Type/Energy Source: Electric.
Comments:
 Est. Size: 2 1/2 ton
 Cooling System- - Central, - Split System.
 AIR TEMPERATURE DIFFERENTIAL- Temperature drop/differential observed between 15 - 20 degrees. (taken between interior return and supply air) This is considered a normal operating range.
 EVAPORATOR OBSERVATIONS-debris at interior blower in need of cleaning/ servicing

- C. Ducts and Vents**
Comments:
 DUCTWORK TYPE- Fiberglass duct board and/or flexible type ducts were primarily used

I=Inspected		NI=Not Inspected		NP=Not Present		R=Not Functioning or in Need of Repair		Inspection Item
I	NI	NP	R					

for distribution/return system throughout.
 Ductwork, Air Chase and/or Plenum Observations-seal all duct connections in attic areas.

IV. PLUMBING SYSTEM

A. Water Supply System and Fixtures
Comments:

The potable water supply source is- Municipal service is primary water source.
 SUPPLY PIPING TYPE- Copper
 POTABLE WATER LINE OBSERVATIONS- Appears serviceable.
 EXTERIOR PLUMBING- No anti-siphon protection observed on rear exterior hose bibs/ faucets. This is a basic safety attachment to the end of faucets that will protect from a cross connection or back-flow of water into the house.

Bathroom #1 HALL BATHROOM:

LAVATORY- No problems observed during this inspection period.
 TOILET PLUMBING- tank loose from bowl at toilet in need of repair
 Water closet fill valve leaking in tank when flushed. Repair/replace valve.
 Toilet is loose at the floor with the possibility of leakage, an unsanitary condition that can also cause damage to flooring. A plumber should resecure the toilet as needed.
 TUB/SHOWER PLUMBING- No problems observed during this inspection period.

Bathroom #2 MASTER BATHROOM:

LAVATORY- stopped up aerator at faucet
 TOILET PLUMBING- Water closet fill valve leaking in tank when flushed. Repair/replace valve.
 Loose tank from toilet in need of repairs.
 TUB/SHOWER PLUMBING-missing stopper at tub.

B. Drains, Wastes, Vents
Comments:

DRAIN/WASTE & VENT PIPING TYPE- PVC plastic
 SEWER PIPE OBSERVATIONS- No problems observed during this inspection period.

Bathroom #1 HALL BATHROOM:

Bathroom #2 MASTER BATHROOM:

C. Water Heating Equipment #1: (Report as in need of repair those conditions specifically listed as recognized hazards by TREC rules.)
Energy Source: Electrically operated.
Comments:

I=Inspected		NI=Not Inspected		NP=Not Present	R=Not Functioning or in Need of Repair	Inspection Item
I	NI	NP	R			

Location/Coverage: Closet, Hallway.

State 40 gallon 2001 unit.
No problems observed during this inspection period.

- | | | | | |
|--------------------------|--------------------------|-------------------------------------|--------------------------|-----------------------------------|
| <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | D. Hydro Therapy Equipment |
| <i>Comments:</i> | | | | |
| Not Present | | | | |

V. APPLIANCES

- | | | | | |
|---|--------------------------|-------------------------------------|-------------------------------------|--|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | A. Dishwasher |
| <i>Comments:</i> | | | | |
| No problems observed during limited test run of appliance. | | | | |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | B. Food Waste Disposer |
| <i>Comments:</i> | | | | |
| Deficiencies-
Splash guard is damaged/missing. | | | | |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | C. Range Hood |
| <i>Comments:</i> | | | | |
| No problems observed during limited test run of appliance. | | | | |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | D. Ranges/Ovens/Cooktops |
| <i>Comments:</i> | | | | |
| Oven present, Electric. No problems observed during this inspection period. | | | | |
| <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | E. Microwave Cooking Equipment |
| <i>Comments:</i> | | | | |
| Not Present | | | | |
| <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | F. Trash Compactor |
| <i>Comments:</i> | | | | |
| Not Present | | | | |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | G. Bathroom Exhaust Fans and/or Heaters |
| <i>Comments:</i> | | | | |
| Vent unit present. No problems observed during limited test run of appliance. | | | | |
| <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | H. Whole House Vacuum Systems |
| <i>Comments:</i> | | | | |

I=Inspected		NI=Not Inspected		NP=Not Present		R=Not Functioning or in Need of Repair		Inspection Item
I	NI	NP	R					

Not Present

I. **Garage Door Operators**
Comments:

Not Present

J. **Door Bell and Chimes**
Comments:

No problems observed.

K. **Dryer Vents**
Comments:

No problems noted.

L. **Other Built-in Appliances**
Comments:

Not Present

VI. OPTIONAL SYSTEMS

A. **Lawn Sprinklers**
Comments:

Not Present

B. **Swimming Pools and Equipment**
Comments:

Not Present

C. **Outbuildings**
Comments:

Not Present

D. **Outdoor Cooking Equipment**
Energy Source:
Comments:

Not Present

E. **Gas Lines**
Comments:

Not Present

I=Inspected		NI=Not Inspected		NP=Not Present	R=Not Functioning or in Need of Repair	Inspection Item
I	NI	NP	R			

F. Water Wells (A coliform analysis is recommended.)

Type of Pump:

Type of Storage Equipment:

Comments:

Not Present

G. Septic Systems

Comments:

Not Present

H. Security Systems

Comments:

security testing is not part of this inspection

I. Fire Protection Equipment

Comments:

Not Present