

PROPERTY INSPECTION REPORT

Prepared For: Tony Scarnato
(Name of Client)

Concerning: 444 Precious San Antonio, TX 78237
(Address or Other Identification of Inspected Property)

By: Gary Armstrong 9604 09/18/07
(Name and License Number of Inspector) (Date)

(Name, License Number and Signature of Sponsoring Inspector, if required)

The inspection of the property listed above must be performed in compliance with the rules of the Texas Real Estate Commission (TREC).

The inspection is of conditions which are present and visible at the time of the inspection, and all of the equipment is operated in normal modes. The inspector must indicate which items are in need of repair or are not functioning and will report on all applicable items required by TREC rules.

This report is intended to provide you with information concerning the condition of the property at the time of inspection. Please read the report carefully. If any item is unclear, you should request the inspector to provide clarification.

It is recommended that you obtain as much history as is available concerning this property. This historical information may include copies of any seller's disclosures, previous inspection or engineering reports, reports performed for or by relocation companies, municipal inspection departments, lenders, insurers, and appraisers. You should attempt to determine whether repairs, renovation, remodeling, additions or other such activities have taken place at this property.

Property conditions change with time and use. Since this report is provided for the specific benefit of the client(s), secondary readers of this information should hire a licensed inspector to perform an inspection to meet their specific needs and to obtain current information concerning this property.

ADDITIONAL INFORMATION PROVIDED BY INSPECTOR

Report Number: 20070939994 Phone Number: _____
Date of Inspection: 09/18/07 Fax Number: _____
Time of Inspection: 4:30pm
Client Mailing Address: _____
City/State/Zip: _____

SPECIAL NOTES:

Additional pages may be attached to this report. Read them very carefully. This report may not be complete without the attachments. If an item is present in the property but is not inspected, the "NI" column will be checked and an explanation is necessary. Comments may be provided by the inspector whether or not an item is deemed in need of repair.

I=Inspected		NI=Not Inspected		NP=Not Present	R=Not Functioning or in Need of Repair	Inspection Item
I	NI	NP	R			

I. STRUCTURAL SYSTEMS

A. Foundations (If all crawl space areas are not inspected, provide an explanation.)
Comments (An opinion on performance is mandatory.):

FOUNDATION TYPE- Concrete slab on grade.
 CONCRETE FOUNDATION OBSERVATIONS- Foundation appears to be functioning normally at time of inspection.
 Minor signs of past settlement observed in the form of hair line type cracking to finished surfaces, at exterior parge coating front entry areas.

B. Grading and Drainage
Comments
 Structure is built on a slightly sloped lot. Grade at foundation appears inadequate at left, at right front areas. . Repair drainage at these areas to properly drain away from foundation, to prevent water accumulation and possible stress to structure.

C. Roof Covering (If the roof is inaccessible, report the method used to inspect.)
Comments
 METHOD USED TO INSPECT ROOF- The following was observed upon walking on the roof.
 DESCRIPTION OF MATERIALS- Composition and/or fiberglass shingles. Note: Average life expectancy under normal installation/conditions is between 10 -14 years. Approximate age of roof. Approximate age of this roof covering is believed to be between 5 and 10 years old.
 ROOF COVERING OBSERVATIONS- Seal all exposed fasteners at ridge caps, flashings on roof.
 Starter strip around perimeter edge of roof improperly installed, not sealed down as per manufacturer installation instructions.
 Roof covering observed showing normal wear for age.

GUTTERING OBSERVATIONS- DAMAGE/DEFECTS NOTED- Extend gutter downspouts properly away from foundation around house. It is recommended to extend 3 to 5 feet away from foundation.

D. Roof Structure and Attic (If the attic is inaccessible, report the method used to inspect.)
Comments
 ACCESS METHOD/LIMITATIONS- Full access
 ATTIC OBSERVATIONS- Truss framing
 ROOF STRUCTURE OBSERVATIONS- No problems observed during this inspection period.
 INSULATION OBSERVATIONS- Blown type insulation (either fiberglass or rock wool) present. The insulation layer is approximately, 5 - 6 inches thick.

I=Inspected		NI=Not Inspected		NP=Not Present	R=Not Functioning or in Need of Repair	Inspection Item
I	NI	NP	R			

9.6" recommended for R30 value in attic. Add properly.

- | | | | | | |
|-------------------------------------|--------------------------|--------------------------|-------------------------------------|---|--|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <p>E. Walls (Interior and Exterior)
<i>Comments</i></p> <p>INTERIOR WALL OBSERVATIONS- INTERIOR WALLS ARE COVERED WITH THE FOLLOWING MATERIAL(S)- Drywall.
OBSERVATIONS-trim damaged at front, at right bedroom
Cracking noted at right side kitchen doorway
Holes, damage at right front bedroom, at right rear bedroom wall</p> <p>EXTERIOR WALL OBSERVATIONS- EXTERIOR WALLS ARE CONSTRUCTED OF THE FOLLOWING MATERIALS- Brick and/or block (stone) veneer over wood framing. Cement Fiber type siding. Soffit(s), eave(s), and/or trim are painted wood
OBSERVATIONS-worn paint noted on exterior surfaces, staining observed at eaves.
Damaged trim at garage exterior
Exposed nails at fascia on exterior.</p> | |
|-------------------------------------|--------------------------|--------------------------|-------------------------------------|---|--|

- | | | | | | |
|-------------------------------------|--------------------------|--------------------------|-------------------------------------|---|--|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <p>F. Ceilings and Floors
<i>Comments</i></p> <p>CEILING COVERING(S)- CEILING OBSERVATIONS-damaged ceiling at living, entry area.</p> <p>FLOOR COVERING(S)-peeling, damaged flooring at kitchen area</p> | |
|-------------------------------------|--------------------------|--------------------------|-------------------------------------|---|--|

- | | | | | | |
|-------------------------------------|--------------------------|--------------------------|-------------------------------------|--|--|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <p>G. Doors (Interior and Exterior)
<i>Comments</i></p> <p>INTERIOR DOOR OBSERVATIONS-front right bedroom door sticking in jamb</p> <p>EXTERIOR DOOR OBSERVATIONS-side door sticking in frame
Front door out of square.</p> | |
|-------------------------------------|--------------------------|--------------------------|-------------------------------------|--|--|

- | | | | | | |
|-------------------------------------|--------------------------|--------------------------|-------------------------------------|--|--|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <p>H. Windows
<i>Comments</i></p> <p>OBSERVATIONS-Staining, fungal type growth observed at left rear window at interior from possible leakage.
Plywood covering right side living room window
Missing screens at rear of house.</p> | |
|-------------------------------------|--------------------------|--------------------------|-------------------------------------|--|--|

- | | | | | | |
|--------------------------|--------------------------|-------------------------------------|--------------------------|--|--|
| <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <p>I. Fireplace/Chimney
<i>Comments</i></p> <p>Not Present</p> | |
|--------------------------|--------------------------|-------------------------------------|--------------------------|--|--|

I=Inspected		NI=Not Inspected		NP=Not Present	R=Not Functioning or in Need of Repair	Inspection Item
I	NI	NP	R			

J. Porches, Decks and Carports (Attached)
Comments
 PORCH OBSERVATIONS- No problems observed during inspection period.

K. Other
Comments
 Not Present

II. ELECTRICAL SYSTEMS

A. Service Entrance and Panels
Comments:
 SERVICE COMMENTS: Under Ground
 MAIN PANEL COMMENTS: LOCATION- Exterior of house at right side.
 PREDOMINANT OVERLOAD PROTECTION DEVICES- Circuit breakers are provided.
 MAIN ELECTRICAL PANEL OBSERVATIONS-white wiring used on hot leg of circuit but not properly marked in panel.

SUB-PANEL COMMENTS: LOCATION- Garage
 SUB-ELECTRICAL PANEL OBSERVATIONS- No problem(s) noted at the time of inspection.

B. Branch Circuits - Connected Devices and Fixtures (Report as in need of repair the lack of ground fault circuit protection where required.)
Comments:
 FEEDERS- Copper, Aluminum (220 volt OK)
 VISIBLE BRANCH WIRING TYPE- Grounded type branch wiring present. Copper
 BRANCH WIRING OBSERVATIONS- WIRING DEFICIENCIES-romex in attic added, not properly secured.
 LIGHTING & CEILING FAN DEFICIENCIES- cover missing at kitchen light fixture.

III. HEATING, VENTILATION AND AIR CONDITIONING SYSTEMS

A. Heating Equipment #1:
Type/Energy Source: System Type- Electric Forced Air Heat Pump.
Comments:
 Unit located at closet.
 Heating System- The heating system operated correctly at the time of the inspection.

B. Cooling Equipment #1:
Type/Energy Source: Electric.
Comments:

I=Inspected		NI=Not Inspected		NP=Not Present	R=Not Functioning or in Need of Repair	Inspection Item
I	NI	NP	R			

Cooling System- - Central, - Split System.
 Trane est 2 1/2 ton 2000 unit located at exterior
 AIR TEMPERATURE DIFFERENTIAL- Air Temperature Deficiencies- **Temperature drop/differential observed to be over 20 degrees. This may indicate dirty evaporator coils, dirty air filter, or air flow restriction. Contact a licensed service company for further evaluation and/or cleaning.**
 EVAPORATOR OBSERVATIONS-debris and fungal type growth observed at interior blower, coils in need of professional cleaning/removal
 CONDENSER (EXTERIOR UNIT) OBSERVATIONS-external coils in need of cleaning/servicing.

C. Ducts and Vents
Comments:

DUCTWORK TYPE- Fiberglass duct board and/or flexible type ducts were primarily used for distribution/return system throughout.
 Ductwork, Air Chase and/or Plenum Observations- **Openings observed at ducts and/or at blower unit allowing air to escape from the system. Seal all joints throughout attic. Electrical wiring was present in the return air duct work from water heater unit installation.**

IV. PLUMBING SYSTEM

A. Water Supply System and Fixtures
Comments:

The potable water supply source is- Municipal service is primary water source.
 SUPPLY PIPING TYPE- Copper, Galvanized
 POTABLE WATER LINE OBSERVATIONS- Appears serviceable.
 EXTERIOR PLUMBING-leaking observed at one exterior hose bibb on house.

Kitchen

KITCHEN SINK PLUMBING- NOTE: Moisture stain(s) and/or damage to cabinet shelf are observed. This is a signs of previous leakage. Mold/mildew may be present.

Bathroom #1 MASTER BATHROOM:

LAVATORY- No problems observed during this inspection period.
 TOILET/BIDET PLUMBING- No problems observed during this inspection period.
 TUB/SHOWER PLUMBING- No problems observed during this inspection period.

B. Drains, Wastes, Vents
Comments:

DRAIN/WASTE & VENT PIPING TYPE- PVC plastic
 SEWER PIPE OBSERVATIONS- No problems observed during this inspection period.

I=Inspected		NI=Not Inspected		NP=Not Present	R=Not Functioning or in Need of Repair	Inspection Item
I	NI	NP	R			

Kitchen
 KITCHEN DRAIN PLUMBING- No problems observed during this inspection period.

Bathroom #1 MASTER BATHROOM:
 LAVATORY- **Restricted/Slow drainage was noted.**
 TOILET/BIDET PLUMBING- No problems observed during this inspection period.
 TUB/SHOWER PLUMBING- No problems observed during this inspection period.

C. Water Heating Equipment #1: (Report as in need of repair those conditions specifically listed as recognized hazards by TREC rules.)
Energy Source: Electrically operated.
Comments:
 State 40 gallon 2000 unit located at closet.
 No problems observed during this inspection period.

D. Hydro Therapy Equipment
Comments:
Not Present

V. APPLIANCES

A. Dishwasher
Comments:
 Unit is not properly secured in cabinet.

B. Food Waste Disposer
Comments:
 No problems observed during limited test run of appliance.

C. Range Hood
Comments:
 No problems observed during limited test run of appliance.

D. Ranges/Ovens/Cooktops
Comments:
 Oven present, Electric.
 No problems observed during this inspection period.

E. Microwave Cooking Equipment
Comments:
Not Present

I=Inspected		NI=Not Inspected		NP=Not Present	R=Not Functioning or in Need of Repair	Inspection Item
I	NI	NP	R			

F. Trash Compactor
Comments:
 Not Present

G. Bathroom Exhaust Fans and/or Heaters
Comments:
 Vent unit present. No problems observed during limited test run of appliance.

H. Whole House Vacuum Systems
Comments:
 Not Present

I. Garage Door Operators
Comments:
 Not Present

J. Door Bell and Chimes
Comments:
 No problems observed.

K. Dryer Vents
Comments:
 No problems noted.

L. Other Built-in Appliances
Comments:
 Not Present

VI. OPTIONAL SYSTEMS

A. Lawn Sprinklers
Comments:
 Not Present

B. Swimming Pools and Equipment
Comments:
 Not Present

C. Outbuildings
Comments:
 Not Present

I=Inspected		NI=Not Inspected		NP=Not Present	R=Not Functioning or in Need of Repair	Inspection Item
I	NI	NP	R			

D. Outdoor Cooking Equipment
Energy Source:
Comments:
 Not Present

E. Gas Lines
Comments:
 Not Present

F. Water Wells (A coliform analysis is recommended.)
Type of Pump:
Type of Storage Equipment:
Comments:
 Not Present

G. Septic Systems
Comments:
 Not Present

H. Security Systems
Comments:
 security testing is not part of this inspection

I. Fire Protection Equipment
Comments:
 Not Present