

PROPERTY INSPECTION REPORT

Prepared For: SAHA

(Name of Client)

Concerning: 506 Matthews San Antonio, TX 78237

(Address or Other Identification of Inspected Property)

By: Jon Krauss 4255 02/20/08

(Name and License Number of Inspector) (Date)

(Name, License Number and Signature of Sponsoring Inspector, if required)

The inspection of the property listed above must be performed in compliance with the rules of the Texas Real Estate Commission (TREC).

The inspection is of conditions which are present and visible at the time of the inspection, and all of the equipment is operated in normal modes. The inspector must indicate which items are in need of repair or are not functioning and will report on all applicable items required by TREC rules.

This report is intended to provide you with information concerning the condition of the property at the time of inspection. Please read the report carefully. If any item is unclear, you should request the inspector to provide clarification.

It is recommended that you obtain as much history as is available concerning this property. This historical information may include copies of any seller's disclosures, previous inspection or engineering reports, reports performed for or by relocation companies, municipal inspection departments, lenders, insurers, and appraisers. You should attempt to determine whether repairs, renovation, remodeling, additions or other such activities have taken place at this property.

Property conditions change with time and use. Since this report is provided for the specific benefit of the client(s), secondary readers of this information should hire a licensed inspector to perform an inspection to meet their specific needs and to obtain current information concerning this property.

ADDITIONAL INFORMATION PROVIDED BY INSPECTOR

Report Number: 20080241908 Phone Number: _____
Date of Inspection: 02/20/08 Fax Number: _____
Time of Inspection: _____
Client Mailing Address: _____
City/State/Zip: _____

SPECIAL NOTES:

Additional pages may be attached to this report. Read them very carefully. This report may not be complete without the attachments. If an item is present in the property but is not inspected, the "NI" column will be checked and an explanation is necessary. Comments may be provided by the inspector whether or not an item is deemed in need of repair.

I=Inspected		NI=Not Inspected		NP=Not Present	R=Not Functioning or in Need of Repair	Inspection Item
I	NI	NP	R			

I. STRUCTURAL SYSTEMS

A. Foundations (If all crawl space areas are not inspected, provide an explanation.)
Comments (An opinion on performance is mandatory.):

FOUNDATION TYPE- Concrete slab on grade.
 CONCRETE FOUNDATION OBSERVATIONS- Foundation appears to be functioning normally at time of inspection.
 Minor signs of past settlement observed in the form of hair line type cracking to finished surfaces. Smaller, fracture cracks to finished floor in garage observed.

B. Grading and Drainage
Comments
 Structure is built on a slightly sloped lot. Grade at foundation appears inadequate at front of house . Repair drainage at these areas to properly drain away from foundation, to prevent water accumulation and possible stress to structure.
 Dry soil observed on exterior of house in need of watering.

C. Roof Covering (If the roof is inaccessible, report the method used to inspect.)
Comments
 METHOD USED TO INSPECT ROOF- The following was observed upon walking on the roof.
 DESCRIPTION OF MATERIALS- Composition and/or fiberglass shingles. Note: Average life expectancy under normal installation/conditions is between 10 -14 years.
 ROOF COVERING OBSERVATIONS- Roof covering observed showing normal wear for age.
 Starter strip around perimeter edge of roof improperly installed, not sealed down.
 Seal all exposed fasteners at ridge caps, flashings on roof.
 Right slope of roof secure and seal one loose plumbing vent penetration
 GUTTERING OBSERVATIONS- damaged elbow on downspout on exterior.
 DAMAGE/DEFECTS NOTED- Gutter(s) are filled with debris. (Leaves, sticks, and/or aggregate.) Debris may have restricted full viewing at some areas.

D. Roof Structure and Attic (If the attic is inaccessible, report the method used to inspect.)
Comments
 ACCESS METHOD/LIMITATIONS- Full access
 ATTIC OBSERVATIONS- Truss framing
 Upper vents not fully trimmed out of roof decking. Trim for full air flow
 ROOF STRUCTURE OBSERVATIONS- No problems observed during this inspection period.
 INSULATION OBSERVATIONS- Blown type insulation (either fiberglass or rock wool) present. The insulation layer is approximately, 8 - 9 inches thick.

I=Inspected		NI=Not Inspected		NP=Not Present	R=Not Functioning or in Need of Repair	Inspection Item
I	NI	NP	R			
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>			<p>E. Walls (Interior and Exterior) <i>Comments</i></p> <p>INTERIOR WALL OBSERVATIONS- INTERIOR WALLS ARE COVERED WITH THE FOLLOWING MATERIAL(S)- Drywall.</p> <p>EXTERIOR WALL OBSERVATIONS- EXTERIOR WALLS ARE CONSTRUCTED OF THE FOLLOWING MATERIALS- Cement Fiber type siding. Soffit(s), eave(s), and/or trim are painted wood. Aluminum/ vinyl siding.</p> <p>OBSERVATIONS-Paint, seal base of wood trim at corners, around house. Hole at right rear lap siding on wall.</p>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			<p>F. Ceilings and Floors <i>Comments</i></p> <p>CEILING COVERING(S)- CEILING OBSERVATIONS- No problems observed during this inspection period.</p>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>			<p>G. Doors (Interior and Exterior) <i>Comments</i></p> <p>INTERIOR DOOR OBSERVATIONS- No problems observed during this inspection period.</p> <p>EXTERIOR DOOR OBSERVATIONS- Breakfast door split jamb at striker area. Moisture related deterioration is present in door(s) and/or related trim in the following area(s). --- breakfast door . Repair damage, reseal exterior and consider cover to protect from elements Front door not fully sealed when closed Bent bottom panel at overhead garage door.</p>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>			<p>H. Windows <i>Comments</i></p> <p>OBSERVATIONS- Water damage at interior, swelling at living room window from leakage Note: breakfast windows have been changed from dual pane to single pane</p>
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>			<p>I. Fireplace/Chimney <i>Comments</i></p> <p>Not Present</p>

I=Inspected		NI=Not Inspected		NP=Not Present	R=Not Functioning or in Need of Repair	Inspection Item
I	NI	NP	R			

J. Porches, Decks and Carports (Attached)
Comments

PORCH OBSERVATIONS- No problems observed during inspection period.

K. Other
Comments

Not Present

II. ELECTRICAL SYSTEMS

A. Service Entrance and Panels
Comments:

SERVICE COMMENTS: Under Ground
 MAIN PANEL COMMENTS: LOCATION- Exterior of house
 PREDOMINANT OVERLOAD PROTECTION DEVICES- Circuit breakers are provided.
 MAIN ELECTRICAL PANEL OBSERVATIONS-white wiring used as hot legs in panel but not properly marked as hot legs.
 Conduit pulled loose at base of meter and exposed wiring observed.

SUB-PANEL COMMENTS: LOCATION- Garage
 SUB-ELECTRICAL PANEL OBSERVATIONS- No problem(s) noted at the time of inspection.

B. Branch Circuits - Connected Devices and Fixtures (Report as in need of repair the lack of ground fault circuit protection where required.):
Comments:

FEEDERS- Copper, Aluminum (220 volt OK)
 VISIBLE BRANCH WIRING TYPE- Grounded type branch wiring present. Copper
 BRANCH WIRING OBSERVATIONS- No problems observed during this inspection period.

III. HEATING, VENTILATION AND AIR CONDITIONING SYSTEMS

A. Heating Equipment #1:
Type/Energy Source: System Type- Electric Forced Air Heat Pump.
Comments:

Unit is located in, closet
 Heating System- The heating system operated correctly at the time of the inspection

B. Cooling Equipment #1:
Type/Energy Source: Electric.
Comments:

I=Inspected		NI=Not Inspected		NP=Not Present	R=Not Functioning or in Need of Repair
I	NI	NP	R	Inspection Item	

Est. Size: 2 1/2 ton
 Cooling System- - Central, - Split System.
 AIR TEMPERATURE DIFFERENTIAL- Temperature drop/differential observed between 15 - 20 degrees. (taken between interior return and supply air) This is considered a normal operating range.
 EVAPORATOR OBSERVATIONS- Debris and fungal type growth observed at interior blower housing in need of proper removal.

C. Ducts and Vents
Comments:

DUCTWORK TYPE- Fiberglass duct board and/or flexible type ducts were primarily used for distribution/return system throughout.
 Ductwork, Air Chase and/or Plenum Observations-seal all duct connections throughout attic.

IV. PLUMBING SYSTEM

A. Water Supply System and Fixtures
Comments:

The potable water supply source is- Municipal service is primary water source.
 SUPPLY PIPING TYPE- Copper
 POTABLE WATER LINE OBSERVATIONS- Appears serviceable.

Bathroom #1 MASTER BATHROOM:

LAVATORY- missing stopper at sink
 TOILET PLUMBING- Toilet is loose at the floor with the possibility of leakage, an unsanitary condition that can also cause damage to flooring. A plumber should resecure the toilet as needed, Water closet fill valve leaking in tank when flushed. Repair/replace valve.
 TUB/SHOWER PLUMBING- missing stopper at tub.
 Shower head stopped up.
 Diverter control stuck on shower setting.

Bathroom #2 HALL BATHROOM:

LAVATORY- No problems observed during this inspection period.
 TOILET PLUMBING- Water closet fill valve leaking in tank when flushed. Repair/replace valve.
 TUB/SHOWER PLUMBING-Missing stopper at tub.

B. Drains, Wastes, Vents
Comments:

I=Inspected		NI=Not Inspected		NP=Not Present	R=Not Functioning or in Need of Repair
I	NI	NP	R	Inspection Item	

DRAIN/WASTE & VENT PIPING TYPE- PVC plastic
 SEWER PIPE OBSERVATIONS- No problems observed during this inspection period.

Bathroom #1 MASTER BATHROOM:

Bathroom #2 HALL BATHROOM:

C. Water Heating Equipment #1: (Report as in need of repair those conditions specifically listed as recognized hazards by TREC rules.)
Energy Source: Electrically operated.
Comments:
Location/Coverage: Closet, Hallway.

State 40 gallon 2001 unit
 No problems observed during this inspection period.

D. Hydro Therapy Equipment
Comments:
Not Present

V. APPLIANCES

A. Dishwasher
Comments:
 No problems observed during limited test run of appliance.

B. Food Waste Disposer
Comments:
 No problems observed during limited test run of appliance.

C. Range Hood
Comments:
 No problems observed during limited test run of appliance.
 Unit not adequately secured in cabinet,

D. Ranges/Ovens/Cooktops
Comments:
 Oven present, Electric. No problems observed during this inspection period.

I=Inspected		NI=Not Inspected		NP=Not Present	R=Not Functioning or in Need of Repair	Inspection Item
I	NI	NP	R			

E. Microwave Cooking Equipment
Comments:
Not Present

F. Trash Compactor
Comments:
Not Present

G. Bathroom Exhaust Fans and/or Heaters
Comments:
 Vent unit present. No problems observed during limited test run of appliance.

H. Whole House Vacuum Systems
Comments:
Not Present

I. Garage Door Operators
Comments:
Not Present

J. Door Bell and Chimes
Comments:
 No problems observed.

K. Dryer Vents
Comments:
 No problems noted.

L. Other Built-in Appliances
Comments:
Not Present

VI. OPTIONAL SYSTEMS

A. Lawn Sprinklers
Comments:
Not Present

B. Swimming Pools and Equipment
Comments:
Not Present

I=Inspected		NI=Not Inspected		NP=Not Present	R=Not Functioning or in Need of Repair	Inspection Item
I	NI	NP	R			
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>			C. Outbuildings <i>Comments:</i> Not Present
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>			D. Outdoor Cooking Equipment <i>Energy Source:</i> <i>Comments:</i> Not Present
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>			E. Gas Lines <i>Comments:</i> Not Present
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>			F. Water Wells (A coliform analysis is recommended.) <i>Type of Pump:</i> <i>Type of Storage Equipment:</i> <i>Comments:</i> Not Present
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>			G. Septic Systems <i>Comments:</i> Not Present
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>			H. Security Systems <i>Comments:</i> security testing is not part of this inspection
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>			I. Fire Protection Equipment <i>Comments:</i> Not Present