



818 S. FLORES ST. SAN ANTONIO, TEXAS 78204 www.saha.org

Procurement Department

## ADDENDUM # 1

To: File 1903-910-51-4902

QQ for: Bulk Waste Area Enclosure for Select Beacon Communities

The following questions are asked:

**Question 1: Will the CMU cells be concrete filled? If the CMU cells are not concrete filled what will keep water from filling the CMU wall up?**

**Answer 1: No. The CMU cells will not be filled, but the tops will be capped.**

**Question 2: Will the CMU be placed directly on the Asphalt?**

**Answer 2: Yes, We recommend vendors go to the properties and verify the placement of the Waste Area Enclosures.**

**Question 3: Will a footing of any kind be required for the CMU walls?**

**Answer 3: No. The enclosures will be directly on the asphalt.**

**Question 4: Do you have a preferred Thickness of Steel/iron/Aluminum for the gates?**

**Answer 4: No, The gates must be "privacy" gates. We don't want the bulk waste visible through the gates.**

**Question 5: Will the gates be painted or galvanized for a finish?**

**Answer 5: Yes. The gates will be metal primer painted black.**

By: Shayne Everett-Endres  
Shayne Everett-Endres, Purchasing Agent

Date: April 3, 2019